

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3230-1518:107

Page 1 of 1

CATEGORY: Leakage Rated Dampers

LISTEE: Prefco Products, Inc., 2823 Route 413, Buckingham, PA 18912
Contact: Richard McNutt (215) 340-1707

DESIGN: Models 5100 leakage rated dampers. Refer to listee's data sheet for detailed product description and operational considerations. Models listed below:

<i>Models</i>	<i>Mounting Position</i>	<i>Rating</i>	<i>Width, In.</i>		<i>Height, In.</i>	
			<i>Min</i>	<i>Max</i>	<i>Min</i>	<i>Max</i>
5150, 5151	V & H	III-250 III-450 IV-250 IV-450	6	36	5	45
5150-U10, 5151-U10	V & H	III-250 III-450 IV-250 IV-450	6	36	5	10
5150-G, 5151-G	V & H	I-350	10	36	10	45
		I-450				
		II-250	6	36	5	45
		II-450				
5150-U10G, 5511-U10G,	V & H	I-350	10	36	10	10
		I-450				
		II-250	6	36	5	10
		II-450				

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as leakage rated dampers for use in heating, ventilating and air conditioning duct systems passing through fire resistive walls and partitions.

05-26-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager